
NHBC - CHAPTER 10.2.6 - TABLE 3

Minimum sub-base thickness for paved areas.		
California Bearing Ratio (CBR) Values	Minimum thickness (mm) of Sub-Base (Consolidated accordance with MCHW Volume 1 clause 801, table 8/1)	
	Without Geotextile Underneath	With Geotextile Underneath
Less Than 2%	N/A	300
2% to 3%	325	225
3% to 5%	250	150
5% to 7%	150	N/A
7% to 20%	100	N/A

C2	18.10.22	Spine formatc detail updated for Tensor Design	JS	RF
C1	12.09.22	Updated to construction issue	JS	RF
REV. No.	DATE	DESCRIPTION	DRAWN	CHECKED

Client				
	Project: Boorley Green Gateway		Status: Ipsium Court, 24 The Quadrant, Abingdon Science Park, Abingdon Oxon, OX14 3YS Tel: 01235 555173 Email: mja@mjaconsulting.co.uk	
Title	Highway Construction Details		Drawn: As Shown @ A0 Scale: A3 Project No: 6663 Date: 11/02/2022 Drawing Number: 6563 - MJA-SW-XX-DR-C-200 Rev: C2	