

Morris, Rachael

From: Oliveira, Marta
Sent: 05 June 2024 12:48
To: Morris, Rachael
Subject: F/24/97033 - BADNAM COTTAGE, HIGH STREET, BURSLEDON, SOUTHAMPTON, SO31 8DJ

Hi Rachael,

I have now had the opportunity to look to the amended drawings dated 29.05.2024 and my comments are as follows:

- I endorse the Built Heritage consultant comments in respect to the significant design enhancement achieved by proposing a steeper roof pitch due to the 'improved balance between wall and roof in elevation'. The design of roofs has a significant impact on the appearance and character of buildings as well as how they relate to the street scene and context in general.
- Also, as referred by the Built Heritage Consultant, the roof covering should be natural slate to maintain a high-quality environment.

I hope these comments are of help.

Kind regards
Marta

Marta Oliveira
Senior Urban Designer

Planning & Environment - Urban/Landscape Design

Ext.: 8032

