

Morris, Rachael

From: Morris, Rachael
Sent: 11 June 2024 09:16
To: Morris, Rachael
Subject: FW: RE: F/24/97452: SAINSBURY'S SUPERMARKET, LEIGH ROAD, EASTLEIGH, SO50 9FH

From: Wedgbury, Stuart < >
Sent: Tuesday, June 11, 2024 9:10 AM
To: Morris, Rachael <Rachael.Morris@eastleigh.gov.uk>
Subject: RE: RE: F/24/97452: SAINSBURY'S SUPERMARKET, LEIGH ROAD, EASTLEIGH, SO50 9FH

Morning Rachel,

The clarification and acoustic report submitted are satisfactory.

I don't anticipate any significant impact upon amenity and so have no comment to make.

Regards

Stuart Wedgbury

Stuart Wedgbury
Environmental Health Specialist
Planning & Environment - Pollution

From: Morris, Rachael <Rachael.Morris@eastleigh.gov.uk>
Sent: Thursday, June 6, 2024 8:30 AM
To: Wedgbury, Stuart < >
Subject: FW: RE: F/24/97452: SAINSBURY'S SUPERMARKET, LEIGH ROAD, EASTLEIGH, SO50 9FH

Hi Stuart,

Please see the attached in response to your consultation.

Please let me know your updated response.

Thank you,
Rachael

Rachael Morris
Senior Planning Officer
Planning & Environment - Planning/Development Management
Ext.: 8463

From: James Tarpy < >
Sent: Wednesday, June 5, 2024 5:22 PM

To: Morris, Rachael <Rachael.Morris@eastleigh.gov.uk>

Subject: RE: RE: F/24/97452: SAINSBURY'S SUPERMARKET, LEIGH ROAD, EASTLEIGH, SO50 9FH

Rachael,

Please see the attached NIA related to the application.

Kind regards

James

JAMES TARPY
Senior Planner

www.alderking.com



Proud to support diversity and inclusion in the property industry.



Privacy Policy

By responding to this email or emailing Alder King LLP, your name and contact information may be collected, stored and used by Alder King LLP for its legitimate business purposes. If there is no business reason why this information should be collected and stored, then please contact the sender of this email. For information about how we collect, store and use your personal data in the delivery of our services and marketing, please review our **Privacy Policy**.

Confidentiality

This email is confidential and/or legally privileged and intended for the use of the addressee only. If you are not the intended recipient or the person responsible for delivering the email to the intended recipient, please advise the sender immediately. The use, dissemination, forwarding, printing or copying of this email is strictly prohibited. Alder King has taken reasonable precaution to ensure that no viruses are transmitted to any third party but accepts no liability for any loss or damage as a result of the use of this email.

Alder King LLP is a Limited Liability Partnership registered in England and Wales No. OC306796. Registered office: Pembroke House, 15 Pembroke Road, Bristol BS8 3BA. A list of members is available at the registered office.

From: James Tarpay

Sent: Wednesday, June 5, 2024 12:04 PM

To: 'Morris, Rachael' <Rachael.Morris@eastleigh.gov.uk>


Subject: RE: F/24/97452: SAINSBURY'S SUPERMARKET, LEIGH ROAD, EASTLEIGH, SO50 9FH [Filed 05 Jun 2024 12:03]

Rachael,

Thank you for getting in contact.

I have contacted the client to get additional information on the ASHPs.

On the air condenser point, it is one unit but it is measured as two parts



Kind regards
James

From: Morris, Rachael <Rachael.Morris@eastleigh.gov.uk>
Sent: Wednesday, June 5, 2024 11:32 AM
To: James Tarp <>
Subject: FW: F/24/97452: SAINSBURY'S SUPERMARKET, LEIGH ROAD, EASTLEIGH, SO50 9FH

Hi,

Please see the below response from our environmental health team regarding your planning application at Sainsbury's Supermarket in Eastleigh.

Please can the below comments be actioned and offer clarification on the description.

Thank you.

Kind regards,
Rachael

Rachael Morris
Senior Planning Officer

Planning & Environment - Planning/Development Management
023 8068 8463



Eastleigh Borough Council | Eastleigh House | Upper Market Street | Eastleigh | SO50 9YN

This email is subject to recording and/or monitoring. Any content or attachments are for the person to whom it is addressed and may be confidential.
If you get it by mistake, please email us back as soon as possible, and then delete it from your system; please do not pass it on to anyone else or use the information in it.
We do our best to guard against viruses. If you get a virus, we cannot accept liability for any damage.
You should carry out your own virus check before you open attachments.

Eastleigh Borough Council

From: Wedgbury, Stuart <>
Sent: Wednesday, June 5, 2024 9:54 AM
To: Morris, Rachael <Rachael.Morris@eastleigh.gov.uk>
Subject: F/24/97452: SAINSBURY'S SUPERMARKET, LEIGH ROAD, EASTLEIGH, SO50 9FH

Dear Rachel

F/24/97452: SAINSBURY'S SUPERMARKET, LEIGH ROAD, EASTLEIGH, SO50 9FH- Installation of [3.no](#) air source heat pumps and [1.no](#) air condenser with associated fencing on the roof of existing store following removal of existing plant. Our Ref - PR202405-104755

Thank you for consulting Environmental Health regarding the above application. I comment upon environmental noise only.

I think it unlikely that the proposal would impact upon amenity in a significant way by virtue of the proposed location and mix of nearby uses.

However, I cannot understand the technical acoustic details submitted. I am directed to drawing RAC-201-GF-DR-N-555-04 for these details. The tabulated data shows two SCM Frigo refrigeration plant and two Kelvion condensers with acoustic information (L_w for the first items and L_{wA} for the second). The drawing however, appears to show two Frigo refrigeration plant but only one Kelvion condenser plant. The drawing also shows three air source heat pumps, but I cannot see any tabulated acoustic data for these. I note also the description of the application above is at odds with my interpretation of this drawing. Can I request the following clarifications from the applicant:

- Please tabulate each item of new plant proposed with the sound power data provided by the manufacturer. This should be 'A' weighted data and can be presented either as a sound power level (L_{wA}) or as a sound level L_{pA} at a specified distance.

Regards

Stuart Wedgbury

Stuart Wedgbury
Environmental Health Specialist
Planning & Environment - Pollution

Barrow Eastleigh 01252 854000