

Eastleigh Borough Council
Eastleigh House
Upper Market Street
Eastleigh
SO50 9YN

Hampshire 2050
The Castle
Winchester, Hampshire SO23 8UD

Telephone: 0300 555 1375
Fax: 01962 847055

www.hants.gov.uk

Enquiries To Matt Grantham

My reference 052804

Direct Line

Your reference A/24/97044

Date 3 June 2024

Email eastleighdc@hants.gov.uk

Dear Mr Huckfield,

103 BOURNEMOUTH ROAD, CHANDLER'S FORD, EASTLEIGH, SO53 3ZJ

Consent to display 10no. non-illuminated fascia signs, 1no. internally illuminated fascia sign, 1no. internally illuminated projecting sign, 1no. non-illuminated ATM surround, 1no. wall-mounted non-illuminated car park sign, 2no. double-sided freestanding entrance/exit signs, and 1no. internally illuminated 3.3m high totem sign

In regard to application A/24/97044, following on from the previous HCC Highway comments dated 01 April 2024, it is noted that an updated plan has been received (02_BOUR_02C-R1) showing revised locations for the 3 of the signs outlined above, being:

- 2no. double-sided freestanding entrance/exit signs; and
- 1no. internally illuminated 3.3m high totem sign.

All signs are now located off of the public highway on private site land, and as such are acceptable in principle.

As previously outlined however, the signage will need to also be reviewed as part of the S278 for the site access work, and if they are found to impact upon these (i.e. obstruct visibility or affect the workings of the traffic signals, there may be a requirement for them to be further relocated. Applicants should be made aware of this.

Information outstanding for the application, is that of the luminance level associated

Director of Hampshire 2050
Garry Westbrook

with the 1no. internally illuminated projecting sign, and it would also be requested that confirmation be provided for the luminance levels of the Totem sign. All signs should have luminance levels below 600cdl/sqm.

Yours sincerely,

Matt Grantham

Director of Hampshire 2050
Gary Westbrook