

Ecology response amended for H/24/97221 27 DARWIN ROAD, EASTLEIGH, SO50 4GZ

Erection of outbuilding

Alex Stone

20/6/24

I have reviewed the drainage plan, and it is acceptable assuming that soakaways are already in use for the main house. If not, then an infiltration test will be required to determine whether they will be successful with this soil type. The 2 linked slim rainwater collection tanks are a very good idea.

Lisa Malter

Ecologist

22/4/24

This site is in both an amber and green impact risk zone for great crested newts. There are records of bats nearby. The area of the garden where the outbuilding is proposed may contain vegetation which could provide habitat for nesting birds.

New exterior lighting should be avoided, but if necessary for security purposes, then the latest updated lighting guidance note (GN08/23) should be followed. This is available at [Guidance Note 8 Bats and Artificial Lighting | Institution of Lighting Professionals \(theilp.org.uk\)](https://www.theilp.org.uk/Guidance%20Note%208%20Bats%20and%20Artificial%20Lighting%20-%20GN08%2023.pdf).

Vegetation affected by the proposal must be cleared outside of nesting bird season (which is usually March-August inclusive). If this is not possible, a suitably qualified ecologist must check for nesting birds no more than 24 hours before vegetation clearance.

If evidence of an active bird's nest is found during construction, a 5 m buffer must be erected around the nest to protect it from disturbance until after the chicks have fledged and left the nest.

A surface water drainage plan is required.

Biodiversity enhancements will be required in accord with Local Plan policy DM 11 and NPPF paragraph 180. A bat brick and a swift brick may be appropriate for this building.

The Bat Conservation Trust recommends installing a bat brick/box at least 4 m above the ground, away from artificial light sources, sheltered from strong winds and exposed to the sun for part of the day, facing south, south-east or south-west. ([https://www.bats.org.uk > our-work > putting-up-your-box](https://www.bats.org.uk/our-work/putting-up-your-box))

Swift nest boxes are best positioned under the eaves or on walls facing north, northeast or north-west out of direct sunlight, five metres above the ground, with clear adjacent airspace so swifts can access them in a high-speed direct flight.

(<https://www.swiftconservation.org/Nestboxes%26Attraction.htm>)

Additional information is available at:

<https://sussexwildlifetrust.org.uk/discover/in-your-garden/article/31>, planting for bats

<https://www.wildaboutgardens.org.uk/sites/default/files/2022-03/WAG16%20Bats%20updated%202022%20WEB.pdf> - Stars of the Night guide to attract bats into your garden

<https://www.rhs.org.uk/science/conservation-biodiversity/wildlife/plants-for-pollinators>

<https://www.bats.org.uk/our-work/buildings-planning-and-development/bat-boxes>

<https://www.hampshireswifts.co.uk/nesting>

<https://www.rspb.org.uk/birds-and-wildlife/advice/how-you-can-help-birds/nestboxes/nestboxes-for-small-birds/>

<https://www.swift-conservation.org/OurLeaflets.htm>

<https://www.hedgehogstreet.org/help-hedgehogs/hedgehog-homes/>

www.bats.org.uk/resources/guidance-for-professionals/landscape-and-urban-design-for-bats-and-biodiversity

<https://ptes.org/my-garden/>

<https://www.ukbutterflies.co.uk/foodplants.php>

Lisa Malter

Ecologist