

Altman, Rebecca

Subject: FW: PN/24/97626- 111 WINCHESTER ROAD, CHANDLER'S FORD, EASTLEIGH, SO53 2GH-

Sent: Friday, August 2, 2024 3:00 PM

To: Altman, Rebecca <rebecca.altman@eastleigh.gov.uk>

Subject: RE: PN/24/97626- 111 WINCHESTER ROAD, CHANDLER'S FORD, EASTLEIGH, SO53 2GH-

Hi Rebecca

We can confirm that all foul drainage would connect to the existing foul drainage system serving the existing building's original toilets.

The surface water will connect to the existing rainwater system for which there is no change in surface area.

I hope this assists

Kindest regards

Tony Allen
Managing Director