

Further information provided by the agent on 06/08/2024

I can see that an acoustic barrier was being discussed however I was wondering if this could be reviewed. This is because another barrier would create a third opposing surface which in turn, under MCS regulations, would increase the sound created by the unit. I have attached a photograph of the location to show the limited options for a barrier location. As it is only 1db over the MCS regulations and the property is in a built up location we believe the impact would be unnoticeable. I would therefore suggest a site visit so that the noise impact of the unit could be reviewed by yourselves. I am happy to discuss this further as well as alternative options.

