

Altman, Rebecca

From: FWM Statutory SWM Consultee mailbox <SWM.Consultee@hants.gov.uk>
Sent: 15 August 2024 15:06
To: Planning @ Eastleigh Borough Council
Cc: Altman, Rebecca
Subject: RE: Planning Application Consultation Request F/24/97312

Dear Rebecca

Thank you for consulting us on this application.

We had previously queried the size of the orifice plates and the risk of blockage. This has now been amended to a hydrobrake with a larger aperture. Calculations and drawings have been provided to demonstrate the drainage still functions at the required return periods and as such this satisfies our previous comment.

Therefore we have no objection to this application

Regards
Sarah

Sarah Reghif
Flood and Water Management - Technical


Universal Services
Hampshire County Council
The Castle
Winchester
Hampshire
SO23 8UD

E-mail: SWM.consultee@hants.gov.uk



[Click here to chat to me on MS Teams](#)

Our vision and values

 Hampshire County Council

Serving the people of Hampshire with **purpose and pride to improve lives** today and for tomorrow.

Working as one organisation	Integrity and respect
Professionalism	Making a difference
Continuous improvement	

Hampshire Services offers a range of professional consultancy services to partner organisations.

www.hants.gov.uk/sharedexpertise

[Copyright](#) Hampshire County Council 2004 [Disclaimer](#) [Privacy Statement](#)

From: Planning (Eastleigh Borough Council) <planning@eastleigh.gov.uk>
Sent: Friday, July 26, 2024 9:57 AM
To: planning@eastleigh.gov.uk
Subject: Planning Application Consultation Request F/24/97312

Caution: This is an external email and could contain malicious content. Do not open any links or attachments if you were not expecting them. If the e-mail looks suspicious, please report via the 'Report Phishing' Button found on your toolbar.

Application No: F/24/97312

Address: Land adjoining 4 Brookfield, Providence Hill, Bursledon.,

Description: Construction of Residential Care Community, comprising a 73-bed care home (Use Class C2) and 5 x 2-bedroom close care cottages (Use Class C3 age restricted), with associated access, internal access road, parking, landscaping and infrastructure.

Would you please let me have your observations on the above application, following receipt of amended plans and supporting documents for this application.

You can access the plans and documents via our portal [F/24/97312](#)

In order to meet the Government's challenging targets for our speed of determining applications, we require any comments you wish to make within 14 days from the date of this memo. Failure to meet this time period will usually result in an application being determined without your comments being considered.

Please reply to the planning officer on the below email address.

Planning Specialist Contact Details

Email: rebecca.altman@eastleigh.gov.uk

Kind regards,

Planning