

Osmond, Gary

From: Bieda, Paul (Contractor)
Sent: 18 August 2024 11:00
To: Osmond, Gary
Subject: PN/24/97696 First Floor 22A Station Road Netley

The Venta Acoustics Noise Impact Assessment of 9 August 2024 addresses the comments of Stuart W e/mail of 9 July.

It specifies increased sound insulation between the commercial ground floor element and the proposed residential units, with commentary that it remains as a retail unit with deliveries no later than 18:00 hours.

The specification requirements for the new windows and vents to mitigate the external commercial noise, achieves average internal noise levels to BS8233.

However, there is one area of concern remaining, the adjacent Netley Central Sports and Social Club [NCSSC] music/entertainment noise emissions were **not present** during the survey, the noise from the social club was **not at a level** which was identifiable above the noise of plant etc.

The NCSSC web site advertises on 10 August 2024 a Classic Rock 'live and loud' event, so a noise survey over that weekend may have shown differing results.

I doubt if music noise is controlled by an automatic limiter although there does not appear to be a history of noise complaints associated with the premises.

Please let me know if you require any further information.

Paul Bieda

Contractor

Pollution Control Specialist

Planning & Environment - Pollution

Ext.: 8155

Mobile: 07721572764

