

Osmond, Gary

From: Panza, Yacklin
Sent: 25 November 2024 15:52
To: Osmond, Gary
Subject: [PR202411-107004] BARTON PEVERIL COLLEGE, CHESTNUT AVENUE, EASTLEIGH, SO50 5ZA - Pollution comments

Hi Gary,

Thanks for consulting the Pollution Team on the planning application F/24/98499 for the Installation of 3no. wind catchers and 2no. Mechanical Ventilation with Heat Recovery (MVHR) Units, along with associated ductwork, guardrail and new roof light on the roof of the Hampshire Building at Barton Peveril College. I will comment on contaminated land and air quality only. Comments on noise will be passed separately in due course.

Contaminated land

The proposed installation of windcatchers and MVHR does not seem to involve any ground disturbance. Therefore, I have no comments on this regard.

Air Quality

The site is located around 1km from an Air Quality Management Area. However, it is noted that the inlet will be towards the existing properties at the back of the building, away from road, which seems to be the most appropriate/the least impactful location. Therefore, I have no concerns on air quality.

I trust the above information is of assistance. If you have any further queries, please do not hesitate in contacting us.

Best regards,

Yacklin

Yacklin Panza

Pollution Control Specialist

Planning & Environment - Pollution

Ext.: 8058

Mobile: 07557 327776

