



Eastleigh Borough Council
Eastleigh House Upper Market Street
Eastleigh
SO50 9YN

Your ref
H/24/98447

Our ref
DSA000038723

Date
26/11/2024

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Single storey rear extension and internal re-ordering works to increase living space.
Site: 27 PEVERELLS ROAD, CHANDLER'S FORD, EASTLEIGH, SO53 2AR.

Thank you for your correspondence dated the 11th of November 2024, please see our comments below regarding the above application.

From reviewing the submitted application, Southern Water has indicated the applicant has a private pipe connected to our existing foul sewer. If the applicant is proposing to use the existing connection. We will have no objections to the works proceeding.

The rising main and manhole requires a minimum clearance of 3 metres on either side of the rising main to protect it from construction works and to allow for future access for maintenance. Please be aware of this for future works.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
southernwater.co.uk/developing-building/planning-your-development