

Osmond, Gary

From: Bieda, Paul (Contractor)
Sent: 27 November 2024 14:01
To: Osmond, Gary
Subject: F/24/98499 Barton Peveril College

Follow Up Flag: Follow up
Flag Status: Flagged

Hi Gary.

I refer to the application for Windcatchers and Mechanical Ventilation Heat Recovery units to the premises.

Windcatchers as described in the Planning Statement Stride Treglown November 2024 are not mechanical and are not referenced in the Plant Noise Impact Assessment Anderson Acoustics November 2024, thus are excluded from comments regarding Environmental Noise Impact.

The acoustic report demonstrates that satisfactory predicted noise levels from the proposed plant at the nearest domestic Noise Sensitive Receptor, are comfortably achieved with No Observed Adverse Effect.

Therefore, I have no objections to the application and recommend that the Anderson Acoustic report be referenced with any approval.

Thanks

Paul Bieda
Contractor
Pollution Control Specialist
Planning & Environment - Pollution
Ext.: 8155
Mobile: 07721572764

