

Harrison, Liz

From: Bieda, Paul (Contractor)
Sent: 27 November 2024 15:47
To: Development Management
Subject: RE: Planning Consultation - EAE047 - Luminous Oak SEMH School, Flycatcher Road, Boorley Gardens, Hedge End, Botley SO32 2FG

I refer to the application, referencing the noise assessment 24 Acoustics 13 November 2024 and comment on Environmental Noise Impact.

The nearest residential Noise Sensitive Receptors [NSR] are in place, the most likely impact will be from the MUGA and sports pitches being used until 20:00 hours.

Although the mitigation described may be satisfactory, the assessment was carried out in February 2023, the one measurement point on the site being furthest from the NSR.

The final construction of the houses may have changed in this period and the reliance on predicted rather than measured noise levels may adversely change the impact, especially the Shooting Noise Levels.

I suggest the noise assessment be brought up to date and resubmitted to the Council with the appropriate commentary.

Thanks

Paul Bieda
Contractor

Pollution Control Specialist

Planning & Environment - Pollution

023 80688155

07721572764



Eastleigh Borough Council | Eastleigh House | Upper Market Street | Eastleigh | SO50 9YN

This email is subject to recording and/or monitoring. Any content or attachments are for the person to whom it is addressed and may be confidential.

If you get it by mistake, please email us back as soon as possible, and then delete it from your system; please do not pass it on to anyone else or use the information in it.

We do our best to guard against viruses. If you get a virus, we cannot accept liability for any damage.

You should carry out your own virus check before you open attachments.

Eastleigh Borough Council