

Harrison, Liz

From: Bieda, Paul (Contractor)
Sent: 23 December 2024 12:05
To: Chris McConnell
Cc: Harrison, Liz
Subject: RE: RE: Planning Consultation - EAE047 - Luminous Oak SEMH School, Flycatcher

Hi Chris.

Further information shows that the actual construction position of the houses has not changed and I accept your commentary that the measured noise levels are still valid.

Therefore, as my e/mail of November 2024, the mitigation described in your report of 13 November is satisfactory and I have no objections to the application regarding Environmental Noise Impact.

Thanks

Paul Bieda
Contractor

Pollution Control Specialist

Planning & Environment - Pollution

Ext.:8155

Mobile: 07721572764



From: Chris McConnell
Sent: 20 December 2024 14:42
To: Bieda, Paul (Contractor)
Cc: Josh Large
Subject: RE: RE: Planning Consultation - EAE047 - Luminous Oak SEMH School, Flycatcher

You don't often get email from chrismcconnell@24acoustics.co.uk. [Learn why this is important](#)

Dear Paul,

Thanks for returning my call and apologies I missed you. As we haven't been able to speak over the phone, please see below our response to your attached comments:

The ambient noise measurement location to the south of the site is considered representative of the nearest houses to the north and west, as the prevailing ambient noise levels are not expected to vary significantly around the site. The noise levels obtained in February 2023 are considered valid, as the overall noise levels are unlikely to have changed following the construction of the nearby houses.

Our standard approach for this type of assessment is to measure the ambient noise levels and then predict noise levels from the new MUGA using library data. The predictions are based on source measurements from other similar MUGA sites, hence this is a robust assessment.

We therefore consider the noise assessment undertaken to be robust and representative.

Please could you confirm that this satisfies your queries?

Kind Regards

Chris McConnell
Principal Consultant



Armstrong House, 3 Bassett Avenue, Southampton, SO16 7DP

DD: 02381 555002 T: 02381 555000

www.24acoustics.co.uk

This communication is confidential and it may contain legally privileged information. If you are not the intended recipient you must not read, print copy or use the communication for any purpose, and you must not disclose its contents to any other person. You must notify 24 Acoustics Ltd by E-Mail forthwith at the above address and then delete this communication permanently from your records. 24 Acoustics Ltd uses virus checking software, and we are not aware that this communication contains any viruses. However, we cannot guarantee that no viruses are present, and we accept no liability for any damage caused by you opening this communication, or any attachments or hyperlinks contained in it. Registered in England & Wales, Registration No 5256773. Registered Office: Armstrong House, 3 Bassett Avenue, Southampton, SO16 7DP.