



from
**Southern
Water** 

Eastleigh Borough Council
Eastleigh House Upper Market Street
Eastleigh
SO50 9YN

Your ref
H/25/98741

Our ref
DSA000040794

Date
07/02/2025

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: First floor extension and addition of front porch.
Site: 9 LARCH CLOSE, WEST END, SOUTHAMPTON, SO30 3RB.

Thank you for your correspondence dated the 30th of January 2025, please see our comments below regarding the above application.

Please see attached our GIS document attached indicates the nearby existing public sewer being the required 3m distance away from the proposed development. Therefore, Southern Water have no objections to the works proceeding.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119)

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
southernwater.co.uk/developing-building/planning-your-development