

Harrison, Liz

From: Griffin, Tim
Sent: 04 July 2024 16:35
To: Harrison, Liz
Cc: Ellison, Mark; Oliveira, Marta; Dyer, Tim
Subject: Re: DC2293657 Land North West of Winchester Road, Boorley Green - Conditions 7 LMMP & 8 Tree Pit Details

Hi Liz,

I have the following minor comments:

Condition 7: Soft Landscape Management & Maintenance Plan

I assume that Lisa will check the document has been amended to suit her comments.

1/ Item 8.15 - Watering trees - increase L per visit per tree from 5L to 20L to ensure pit well soaked. Add in bold text 'To avoid failures particular attention given to watering new trees in first 2 years after planting'.

Condition 8: Tree Pit Details

Dwg. No. MILL22453 11P Sheet 1

a/ For clarity, please complete the cross ref. to tree pit Detail 1 for various tree symbols shown on the legend (Details 2 & 3 already noted).

b/ Tree pit volumes for all trees in hard landscape to be shown on plan (only shown for some trees at the moment).

Dwg. No. MILL22453 11P Sheet 2

c/ For ease of reference for Details 2 & 3 (Trees in hard landscape) please list drawing Sheets on which such trees occur so they can be easily located.

KR Tim

Landscape Consultant

Working on behalf of Eastleigh Borough Council

Mobile: 07974 900280