	Luminaire A
Supplier	Philips
Type	BVP651 DX50
Lamp(s)	LED-HB 5.1S
Lamp Flux (klm)	80.00
Maintenance Factor	1.00
No. in Project	4

Crown copyright 2021. Supplied by copla ltd trading as UKPlanningMaps.com a licensed Ordnance Survey partner (100054135).

8514896102

Abbrevi

wl	brick wall
bol	bollard
bs	bus stop
ci	bt inspection ch
cty	cable tv cover
d	drainage channe
dk	dropped kerb
d	diameter
ep	electricity pole
er	earth rod
fb	flower bed
fh	fire hydrant
fp	footpath
g	gully
gbc	gas stop cock
gv	gas stop valve
h	hydrant
ic	inspection chan
jbx	junction box
kb	kerb
lbx	letter box
lp	lamp post
mh	manhole
mkr	marker
h	height
p	post
pb	post box
lp	lamp post

Line typ

DFL
·LIGHTING DESIGN·ELECTRICAL·SMART CITIES·
ENERGY REDUCTION·LIGHTING IMPACT

PROJECT NAME:
Broadway Farm, Botley

PROJECT No:
3850-DFL-ELG-XX-LD-EO-13001

SCALE:
1:1000

DATE:
28 February 2025

CALCULATION:
Horizontal Illuminance (lux)

DESIGNER:
DFL-UK (SP)

Indicative light spill diagram.
> Not for construction.
> Initial light levels shown.
> Light spill diagram does not consider blocking or shading effects of light limiting objects and represents worst-case horizontal light spill at ground floor level.
> Light spill diagram to be read in conjunction with Lighting Strategy: 3850-DFL-ELG-XX-RP-EO-13001-S3

Isolux contours shown:
10 Lux: Blue
5.0 Lux: Green
1.0 Lux: Red
0.5 Lux: Purple
0.2 Lux: Yellow

Page Size: A3
Scale: 1:1000

CHECKED BY:
AJB

APPROVED BY:
RC

REVISION:
P01

SUITABILITY:
S3

PREPARED BY:

DFL-UK
+44 (0)1962 855080
17/18 City Business Centre,
Winchester Hants,
SO23 7TA.
e-mail: info@dfl-uk.com
website: www.dfl-uk.com