

Eastleigh Borough Council
Eastleigh House
Upper Market Street
Eastleigh
SO50 9YN

Enquiries to	Matt Grantham	My reference	056489
Direct Line	N/A	Your reference	A/25/99217
Date	28 April 2025	Email	eastleighdc@hants.gov.uk

For attention of Mr Huckfield

Dear Sirs

Re: A/25/99217 At Parfetts, Tollbar Way,, Hedge End, SO30 2UH

Display of 5 no. internally illuminated fascia signs, 5no. non-illuminated fascia signs, and various other non-illuminated direction and informative signage.

In regard to application A/25/99217, having reviewed the information contained within the application pack, there would be no objection to the proposals from a highway perspective, subject to the condition outlined below.

All proposed signs are positioned flat to the building structure, and as such do not obstruct any movement below.

In terms of the illuminated signs however, no information is currently available on the EBC Planning Portal in terms of the luminance levels proposed (only the 'Proposed Signage Elevations Plan and Site Location Plan are available – i.e. no application form), and as such an assessment in this regard cannot be undertaken.

Given this, it would be requested that the condition outlined below should be applied.

CONDITION:

AMOUNT OF ILLUMINATION

The illumination of the consented sign(s) shall be no greater than 600 candela per square metres and no light source shall be visible from the highway.

Reason: In the interests of highway safety/amenity.

Yours faithfully,

Matt Grantham
Principal Transport Planner - Highway Development Planning
Hampshire 2050