

Vallis, Charlie

To: Malter, Lisa
Subject: RE: HRA - 2 Oakbank Cottage - H/25/99050

From: Malter, Lisa
Sent: 12 May 2025 11:06
To: Vallis, Charlie
Subject: RE: HRA - 2 Oakbank Cottage - H/25/99050

Hi Charlie,
This looks fine and should be sufficient to limit the impacts on the River Itchen SAC and SSSI.

I just have a few corrections:

- Mixers/barrows and shovels must not be washed off on site, unless this is within a skip. Please add that the concrete washing water must not be disposed of on site but must be removed from the site and disposed of in an appropriate waste facility. As this is just a small project, it may be easier to use a smaller container, such as a bucket with a tight fitting lid than a skip to contain the contaminated water and remove it from site.

Rough plant at an angle not greater than 45 degrees (can write out or use the insert symbol in word). The plank and capping the pipes only need to be done at night, but each excavation must be checked by a named person (usually site manager) every morning to ensure that no animals are present.

Kind regards,
Lisa

Lisa Malter
Ecologist (Mon, Tue, Weds, Thu)
Neighbourhoods & Green Spaces - Ecology/Biodiversity