

Harrison, Liz

From: FWM Statutory SWM Consultee mailbox <SWM.Consultee@hants.gov.uk>
Sent: 02 June 2025 09:37
To: Harrison, Liz
Subject: FW: Planning Application Consultation Request X/24/97426

Dear Liz

I've reviewed the information on the planning portal and can see the amended layout for area 3D on the open spaces plan. However, this does not appear to be reflected in the drainage plans and given the nature of the alterations, I would expect these to be updated to reflect the current layout.

On this basis, I would not recommend the variation of condition until the drawings and calculations are updated accordingly. I would also expect to see a short note detailing the changes and demonstrating compliance with previously agreed drainage parameters.

Regards
Sarah

Sarah Reghif
Flood and Water Management - Technical

Universal Services
Hampshire County Council
The Castle
Winchester
Hampshire
SO23 8UD

E-mail: SWM.consultee@hants.gov.uk



[Click here to chat to me on MS Teams](#)

Our vision and values

 Hampshire County Council

Serving the people of Hampshire with **purpose and pride to improve lives** today and for tomorrow.

Working as one organisation	Integrity and respect
Professionalism	Making a difference
Continuous improvement	

Hampshire Services offers a range of professional consultancy services to partner organisations.

www.hants.gov.uk/sharedexpertise

Copyright Hampshire County Council 2004 [Disclaimer](#) [Privacy Statement](#)