

Altman, Rebecca

Subject: FW: F/24/98678 Land East of Chickenhall Lane, Eastleigh, SO50 6AF
Attachments: 101358v03 Chickenhall Lane_Noise Impact Assessment Addendum_Issue.pdf

Sent: 17 June 2025 15:28

Subject: RE: F/24/98678 Land East of Chickenhall Lane, Eastleigh, SO50 6AF

Hi Rebecca

Attached is the corrected noise assessment addendum that includes the proposed increase HGV traffic relating to the recycling centre calculations regarding F/24/98678 Land East of Chickenhall Lane, Eastleigh, SO50 6AF.

Can you please add this file to the case.

I reviewed this addendum and can confirm the noise calculations are based on the HGV traffic flows provided from Paul Basham Associates letter dated 28 May 2025. The difference in noise is marginal and I have no concerns regarding this specifically. Is important to note that a HVAC system is proposed that provides ventilation and colling. This system is key to achieve the noise criteria, and we should make sure this is installed and maintained.

Following my previous email, as you know by now, this site will require considerable heavy mitigation in terms of acoustic glazing and mechanical ventilation (mechanical cooling) and the outside amenity areas only reach the external amenity noise criteria due to proposed garden walls and garden rooms. There is no actual external amenity area that meets the noise criteria.

Thank you

Andre

Andre Pires
Pollution Control Manager
Planning & Environment - Pollution