

**Altman, Rebecca**

---

**Subject:** FW: Block A2 / A3 amendments S73 application ref. X/25/99588 - Lower Acre

---

**Sent:** 24 July 2025 09:16

**Subject:** RE: Block A2 / A3 amendments S73 application ref. X/25/99588 - Lower Acre

Good morning  
Thank you Rebecca,

There are significant changes on windows dimensions, and this must be reviewed by the acoustic consultant to make sure the proposed glazing still meets the noise criteria.

Andre

**Andre Pires**  
**Pollution Control Manager**  
Planning & Environment - Pollution  
**Ext.: 8436**  
**Mobile: 07795985497**