

Altman, Rebecca

Subject: FW: DC/25/99738 9, Southpoint, Ensign Way, Hamble, SO31 4RF - Discharge of conditions 2A and 4A and 4B

Sent: 23 July 2025 09:59

Subject: DC/25/99738 9, Southpoint, Ensign Way, Hamble, SO31 4RF - Discharge of conditions 2A and 4A and 4B

Good morning Rebecca,

Thanks for consulting the Pollution team on the application DC/25/99738 to discharge of Conditions 2a (Acoustic Enclosure Specification), and 4 a & b (Noise Testing) of permission ref. PN/25/99086 for Change of Use of Class E office floor space to 4 x residential flats (Class C3) Under Part 3, Class MA of the General Permitted Development Order.

I review the Noise Control Proposal by Sound Advice Acoustics Ltd reference SAE-1512 dated 02/06/2025 that specifies and designs the proposed acoustic enclosure to mitigate the plant operational noise as requested in Condition 2a.

I also reviewed Sound Advice Acoustics Ltd Airborne Sound Insulation tests reference SA.SI.106.101326 dated 15/07/2025 and I can confirm the party wall meets the sound insulation criteria of Approved Document E as requested by Condition 4A and Condition 4B.

Conditions 2A, Condition 4A and 4B can be discharge.

Regarding Condition 3 and the post completion noise assessment. I would highly recommend that a third-party acoustic consultancy company to carry out this work and not Sound Advice Acoustics Ltd for the simple reason that Sound Advice Acoustics Ltd designed and are providing the acoustic enclosure and would be in the best interest to all parties for a separate entity to test it and discharge condition 3.

Thank you

Andre

Andre Pires

Pollution Control Manager

Planning & Environment - Pollution