

Eastleigh Borough Council  
Eastleigh House  
Upper Market Street  
Eastleigh  
SO50 9YN

Hampshire 2050  
The Castle  
Winchester, Hampshire SO23 8UL  
Telephone 0300 555 1375  
Fax 01962 847055  
[www.hants.gov.uk](http://www.hants.gov.uk)

|              |                   |                |                                                                        |
|--------------|-------------------|----------------|------------------------------------------------------------------------|
| Enquiries to | Matt Grantham     | My reference   | 057893                                                                 |
| Direct Line  | N/A               | Your reference | DC/25/100069                                                           |
| Date         | 24 September 2025 | Email          | <a href="mailto:eastleighdc@hants.gov.uk">eastleighdc@hants.gov.uk</a> |

**For attention of Mr Chapman**

Dear Sirs

**Re: DC/25/100069 At LARKBY, KEW LANE, BURSLEDON, SOUTHAMPTON, SO31 8DD**

**Discharge of Conditions 4 (Arboriculture Method Statement), 5 (Construction Management Scheme), 6 (Surface Water Drainage) and 7 (Foul Connection) of application F/22/93962 (Construction of a replacement dwelling following the demolition of the existing dwelling with associated landscape works) allowed at Appeal on 12th June 2024.**

In regard to application DC/25/100069, specifically the highway related discharge of condition 5 – Construction Management Scheme, this has been reviewed and the following amendment would be requested.

Section 4.3 outlines that 'Wheel washing facilities will be provided at the entrance to reduce the transference of mud/dust onto highways'. Whilst this infrastructure is welcomed, there is the potential for such methodology to fail, particularly during wet weather periods.

As such, it would be requested that the point is updated along the lines of:

'Wheel washing facilities will be provided at the entrance to prevent the transference of mud/dust onto highways. Should this fail, mechanical road sweepers will be employed to clean the highway at the earliest convenience'.

If this update can be made, then there would be no objection to the Discharge of Condition 5 from a highway perspective.

Yours faithfully,

Matt Grantham  
Principal Transport Planner - Highway Development Planning  
Hampshire 2050

Deputy Chief Executive and Director of Hampshire 2050  
**Gary Westbrook**