

Altman, Rebecca

Subject: FW: Response To Application Number DC/25/100377 at HAPPY DAYS NURSERY,
NAIRN ROAD, BOTLEY, SOUTHAMPTON, SO32 2SH

Sent: 16 December 2025 14:07

Subject: RE: Response To Application Number DC/25/100377 at HAPPY DAYS NURSERY, NAIRN ROAD, BOTLEY,
SOUTHAMPTON, SO32 2SH

Thank you for this Rebecca

All the additional information is OK.

I would like to add that the Condition states “ *at least 10dB below background noise levels*” the conclusion of the noise report is that the plant is exactly 10dB below background noise levels at the closest residential receptor. This does not leave any leeway for calculations tolerance etc

This site can be considered low risk as the plant only operates daytime. For this reason, I find this just about acceptable and accept the condition to be discharge.

Thank you

Andre

Andre Pires
Pollution Control Manager
Planning & Environment - Pollution
